



Certificate of Compliance

Certificate: 2016623 **Master Contract:** 158031
Project: 80170321 **Date Issued:** 06/08/2023
Issued to: Watlow Electric Manufacturing Company
1241 Bundy Blvd
Winona, Minnesota 55987
United States
Attention: Larry Glentz

The products listed below are eligible to bear the CSA Mark shown



Issued by: *Vasyl Dykman*
Vasyl Dykman

PRODUCTS

C481302 TEMPERATURE-INDICATING AND REGULATING EQUIPMENT - Other Than Appliance Type

Temperature Controllers, Model Series PM followed by followed by 3, 4, 6, 8 or 9 followed by any letter or number, followed by 1, 2, 3, 4, followed by A, C, E, F or K, followed by A, C, H, J or K, followed by any letter or number, followed by A, C, J, L, M, P, R or T, followed by A, C, E, F or K, followed by A, C, H, J, or K, followed by any letter or number, followed by AA or XX where XX is any alphanumeric character. The front panel of these devices are Type 1, Type 4 (Indoor Use Only) approved for indoor use when properly mounted with integrated gasket.

Models	Input Voltage (V)	Frequency	Input Power (VA)
PM3, PM6	15 to 36	DC	10
	24	50/60Hz	10
	100 to 240	50/60Hz/DC	10
PM4, PM8, PM9	15 to 36	DC	14
	24	50/60Hz	14
	100 to 240	50/60Hz/DC	14



Certificate: 2016623

Master Contract: 158031

Project: 80170321

Date Issued: 06/08/2023

Temperature Controllers, Model Series EZK followed by B, C, D or E followed by L or H, followed by any letter or number, followed by any two numbers or letters, followed by A, followed by any letter or number, followed by any two letters or numbers. The front panel of these devices are Type 1, Type 4 (Indoor Use Only) approved for indoor use when properly mounted with integrated gasket.

Models	Input Voltage (V)	Frequency	Input Power (VA)
EZK	15 to 36	DC	10VA
	24	50/60Hz	10VA
	100 to 240	50/60Hz/DC	10VA



Certificate: 2016623

Master Contract: 158031

Project: 80170321

Date Issued: 06/08/2023

APPLICABLE REQUIREMENTS

CSA C22.2 No. 24-15 (Ninth edition) (R2019) - Temperature-indicating and -regulating equipment

CSA C22.2 No. 0 - General requirements — Canadian Electrical Code, Part II



Certificate: 2016623

Master Contract: 158031

Project: 80170321

Date Issued: 06/08/2023

Notes:

Products certified under Class C481302 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca

